

FIRE PREVENTION BUREAU

MONTHLY REPORT

APRIL 2014

New Businesses

6440 Main #200 — 1-2-1 Card

7350 Janes #B — Hakwood

4200 Commerce #100 — Provident Spend Management

1992 University — DME Elevator & Lifts

1011 Warrenville #195 — Judlau Contracting Inc.

5401 Patton #103 — Leo Exterior Restoration

2200 Western #280 — HNTB Corporation

1111 Burlington #108G-I — Piggy Toes

New Construction Projects

Walmart — Renovation

5730 College — BU Business Building

5515 Main — Hardees

Ogden and Karnes — Arbor Place of Lisle

St. Joan of Arc — Interior renovations

701 Warrenville, Floors 1, 2, 3 — Interior demolition

2375 Cabot, 1st Floor — Interior remodel

4200 Commerce #102 — Interior remodel

4820 Venture — Mezzanine demolition

2300 Cabot, 5th Floor — Interior remodel

Points of Interest

Jaeger Hall at Benedictine University (right) has this unusual assortment of fire department connections and controls. The standard FDC with the double female connections is how we supply water to the system. The WYE, with two male connections, is how the system would supply hose lines. In the middle is a control valve which opens the WYE to allow water into the connected hose lines.

Code Enforcement Activities

Activity	Current	YTD
Inspections (Existing)	250	872
Inspections (New)	27	82
Plan Reviews	38	111
Knox Box Updates	91	410
Hazard Investigations	29	145
Code Meetings	28	124
System Follow Ups	132	373

Public Education Activities

Activity	Current	YTD
Fire Safety Talk or Demo	1	10
Fire Station Tour	5	20
Fire Extinguisher Training	0	0
Fire Drill	0	0
Miscellaneous Public Education	1	1

