



FIRE PREVENTION BUREAU

MONTHLY REPORT

FEBRUARY 2016

New Businesses

901 Warrenville #105 — Palmer Consulting Group LLC

4912-B Main — The Room

4813 Kingston — Tecta America Illinois Roofing LLC

Construction Projects

1010 Burlington/4755 Main — Main Street Village

8099 Janes — Woodridge Horizon Senior Living

8201 Janes — Woodridge Park District ARC

4100 RT 53 — Morton Arboretum South Farm

1500 Maple — Restaurant Remodel

901 Warrenville #420 — Office Remodel

1650 Maple — Restaurant Remodel

2225 Ogden — Office Remodel

2443 Warrenville #130 — Office Remodel

3014 Hobson — Interior Remodel

801 Warrenville #150 — Office Remodel

4513 Western — Access Control Installation

Points of Interest

At the Illinois Tollway Building (right) they disconnected the fire sprinkler system in the main electrical room. The IBC/IFC section 903.3.1.1.1 is correlated to NFPA 13 in that it exempts sprinklers from being required in generator and transformer rooms that are a 2-hour fire-rated enclosure. When this exemption is used, the IBC/IFC requires the room to be protected with an automatic fire detection system that will respond to visible or invisible particles of combustion.

Code Enforcement Activities

<i>Activity</i>	<i>Current</i>	<i>YTD</i>
Inspections (Existing)	186	313
Inspections (New)	21	71
Plan Reviews	25	44
Knox Box Updates	96	176
Hazard Investigations	25	73
Code Meetings	29	59
System Follow Ups	154	268

Public Education Activities

<i>Activity</i>	<i>Current</i>	<i>YTD</i>
Fire Safety Talk or Demo	1	2
Fire Station Tour	2	2
Fire Extinguisher Training	0	0
Fire Drill	0	0
Miscellaneous Public Education	0	0

