



FIRE PREVENTION BUREAU

MONTHLY REPORT

JULY 2014

New Businesses

- 2250 Maple — Benet Academy Spirit Store
- 2300 Cabot #148 — Veritas Steel LLC
- 4710 Main #2&3 — Crème de la Crème Gifts
- 3300 Ogden #200 — Simple Skin Solutions

New Construction Projects

- Walmart — Renovation
- 5730 College — BU Business Building
- 5515 Main — Hardees
- Ogden and Karnes — Arbor Place of Lisle
- 4300 Lincoln — New retail building
- 430 Ogden — Interior remodel
- St. Joan of Arc — Interior renovations
- 4710 Main — Interior remodel
- 801 Warrenville #400 — Interior remodel
- 4225 Naper #136 — Interior remodel
- 2200 Cabot #100 — Interior remodel
- 1040 Maple — Interior remodel
- 2400 Ogden — Interior remodel

Points of Interest

Heat detectors (right) are required to be mounted on ceilings having smooth ceiling construction. Open-web bar joists are considered smooth ceilings because they are incapable of trapping heat. The device pictured has been incorrectly mounted on the bottom of a bar joist and held in a vertical position with a wire tie. All detection devices shall be installed in accordance with the manufacturers listing and NFPA 72 (the fire alarm code).

Code Enforcement Activities

<i>Activity</i>	<i>Current</i>	<i>YTD</i>
Inspections (Existing)	257	1620
Inspections (New)	16	149
Plan Reviews	40	223
Knox Box Updates	124	741
Hazard Investigations	36	249
Code Meetings	34	211
System Follow Ups	71	644

Public Education Activities

<i>Activity</i>	<i>Current</i>	<i>YTD</i>
Fire Safety Talk or Demo	3	26
Fire Station Tour	2	22
Fire Extinguisher Training	0	0
Fire Drill	2	15
Miscellaneous Public Education	0	4

