



FIRE PREVENTION BUREAU

MONTHLY REPORT

NOVEMBER 2015

New Businesses

4225 Naper #230 — Waddell and Reed

3333 Warrenville #750 — HCL

4225 Naper #125 — iMortgage

2801 Ogden — Dunkin Doughnuts

801 Warrenville #240 — Penske

Construction Projects

1010 Burlington/4755 Main — Main Street Village

8099 Janes — Woodridge Horizon Senior Living

8201 Janes — Woodridge Park District ARC

4100 RT 53 — Morton Arboretum South Farm

1800 Robin — Critical equipment relocation

2500 Cabot — Lobby Remodel

2801 Ogden #3 — Lobby Remodel

1500 Maple — Restaurant Remodel

2225 Wellington — Office Remodel

4225 Naper #230 — Office Remodel

2225 Ogden — Office Remodel

1103 Maple — Restaurant Construction

Points of Interest

Hawthorne Ridge has upgraded four units to be fully ADA compliant. Part of this involves the fire alarm (right). AV devices are required in the living room, bedroom, and bathroom. These will activate on any alarm in the building. The device in the bedroom is at a lower frequency, which has been found to be more effective at waking people up. If this device is within two feet of the ceiling it must have a brighter setting, to penetrate a smoke layer. There is also a local 110V smoke detector that has a built-in AV device. Unfortunately, a wall mounted device was improperly installed on the ceiling.

Code Enforcement Activities

<i>Activity</i>	<i>Current</i>	<i>YTD</i>
Inspections (Existing)	125	1814
Inspections (New)	20	290
Plan Reviews	38	416
Knox Box Updates	77	816
Hazard Investigations	36	377
Code Meetings	29	239
System Follow Ups	100	1051

Public Education Activities

<i>Activity</i>	<i>Current</i>	<i>YTD</i>
Fire Safety Talk or Demo	2	19
Fire Station Tour	1	10
Fire Extinguisher Training	0	4
Fire Drill	0	34
Miscellaneous Public Education	0	19

